



June 17, 2025

RECOGNITION FOR FIRE INSURANCE GRADING RECEIVED

Township of Leeds and the Thousand Islands
Leeds 1000 Islands Fire Service

Superior Tanker Shuttle Service - Accredited

I am pleased to advise you that the above mentioned fire protection district within the province of Ontario was recently registered in the fire insurance grading index as being accredited for the delivery of Superior Tanker Shuttle Service.

The requirements for this accreditation are stringent and verify that the fire protection district is capable of delivering the minimum accepted fire flows to detached dwellings throughout the fire protection district and within 8 kilometres by road of the below accredited Fire Station. An application towards Commercial Lines (PFPC) insurance has also been achieved by exceeding the 400 IGPM PFPC flow rate requirements. This accreditation is an equivalency to the minimum requirements for hydrant protection, as set out by the insurance industry and the Fire Underwriters Survey.

Fire Underwriters Survey has provided information on fire protection and risk levels to the insurance industry in Canada since 1883. Fire Underwriters Survey was previously operated under the auspices of the Insurers Advisory Organization and CGI; however, is now operated by SCM Opta Information Intelligence.

Should you have any questions or concerns related to the Fire Underwriters Survey, the Superior Tanker Shuttle Service Accreditation process or any other related area, please contact the offices of Fire Underwriters Survey for further information.

Please note that this accreditation expires on October 23, 2026 and is valid for the following fire station:

- Fire Station #1 - 1233 Prince St., Lansdowne. ON K0E 1L0
- Fire Station #2 - 3306 County Rd 32, Seeley's Bay, ON K0H 2N0
- Fire Station #3 - 153 County Rd. 32, Gananoque. ON K7G 2V3
- Fire Station #4 - 312 Lyndhurst Rd., Lyndhurst. ON K0E 1N0.

Personal Lines Fire Insurance Classification – DPG 3B(S) – Flow Rate of 444 IGPM

Commercial Lines Fire Insurance Classification – PFPC 7(S) – Flow Rate of 444IGPM

Mark Radejewsky
Fire Protection Specialist
Fire Underwriters Survey

<p>Western Canada 3999 Henning Drive Burnaby, BC V5C 6P9 1 (800) 665-5661</p>	<p>Ontario 175 Commerce Valley Drive West Markham, ON L3T 7P6 1 (800) 268-8080</p>	<p>Quebec 1611 Cremazie Boulevard East Montreal, QC H2M 2P2 1 (800) 263-5361</p>	<p>Atlantic Canada 238 Brownlow Avenue, Suite 300 Dartmouth, NS B3B 1Y2 1 (800) 639-4528</p>
--	---	---	---