

Section 11. ANNUAL REPORT.

Drinking-Water System Number:	210001022
Drinking-Water System Name:	Lansdowne Drinking Water System
Drinking-Water System Owner:	Township of Leeds and The Thousand Islands
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1 to December 31, 2017

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [x]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> Available at the Township of Leeds & the Thousands Islands Office, located at 1233 Prince Street, Lansdowne, Ontario and on their website: www.leeds1000islands.ca </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
--	--

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
n/a	n/a

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No [] N/A [x]

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

Lansdowne's Drinking Water System consists of two groundwater water wells which are considered to be under the direct influence of surface water (GUDI). As such, the water treatment system was upgraded in 2010 to include cartridge filtration and an ultraviolet disinfection system. As water is used throughout the distribution system, and the water level in the standpipe falls to a preset limit, the duty well pump starts. Raw water from the well is pumped through two of three cartridge filter trains and then through one of two ultraviolet disinfection units. Sodium hypochlorite is added to provide secondary disinfection. The treated water is then directed through a feedermain to refill the standpipe.

List all water treatment chemicals used over this reporting period

Sodium hypochlorite was used at an average dosage rate of 2.64 mg/L.

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

- Rebuilt 3 hydrants
- Purchased UV sensor kit
- Replaced UV ballast, bulbs & quartz sleeve
- Purchased chlorine analyzer rebuild kit
- Repaired chemical feed pump
- Purchased backflow preventer rebuild kit
- Repaired wiper blades on turbidity analyzer
- Repaired watermain valve boxes and curb stop valves
- Performed leak detection in the distribution system
- Repaired watermain break on Church Street
- Installed cathodic protection on service laterals and mains
- Replaced float and sump pump in standpipe valve chamber
- Repaired transformer in standpipe valve chamber
- Replaced water line on standpipe pressure transmitter
- Replaced aviation lights on standpipe
- Replaced UPS batteries
- Upgraded exterior lighting

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
01/11/2017	Sodium	66.3	mg/L	Resample	01/19/2017

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of <i>E. coli</i> Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	104	0 - 0	0 - 5	n/a	n/a
Treated	52	0 - 0	0 - 0	52	<10 - 80
Distribution	104	0 - 0	0 - 0	52	<10 - 30

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Raw Turbidity	8760	0.12 - 0.60 NTU
Filter #1 Turbidity	8760	0 - 0.55 NTU
Filter #2 Turbidity	8760	0 - 0.87 NTU
Filter #3 Turbidity	8760	0 - 0.60 NTU
Treated Chlorine	8760	0.81 - 5.00 mg/L
Distribution Chlorine	8760	0.46 - 2.74 mg/L

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
n/a				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	01/09/2017	<0.0001	mg / L	No
Arsenic	01/09/2017	0.0002	mg / L	No
Barium	01/09/2017	0.1157	mg / L	No
Boron	01/09/2017	0.038	mg / L	No
Cadmium	01/09/2017	<0.0002	mg / L	No
Chromium	01/09/2017	<0.002	mg / L	No
*Lead	n/a	n/a	mg / L	No
Mercury	01/09/2017	<0.00002	mg / L	No
Selenium	01/09/2017	0.001	mg / L	No
Sodium	01/17/2017	73.4	mg / L	Yes
Uranium	01/09/2017	0.00205	mg / L	No

Fluoride	01/11/2017	0.4	mg / L	No
Nitrite	10/02/2017	<0.1	mg / L	No
Nitrate	10/02/2017	0.6	mg / L	No

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems.

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing	n/a	n/a	n/a
Distribution	2	0.00016 - 0.00038 mg/L	0

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	01/09/2017	<0.3	µg / L	No
Atrazine + N-dealkylated metabolites	01/09/2017	<0.5	µg / L	No
Azinphos-methyl	01/09/2017	<1	µg / L	No
Benzene	01/09/2017	<0.5	µg / L	No
Benzo(a)pyrene	01/09/2017	<0.005	µg / L	No
Bromoxynil	01/09/2017	<0.3	µg / L	No
Carbaryl	01/09/2017	<3	µg / L	No
Carbofuran	01/09/2017	<1	µg / L	No
Carbon Tetrachloride	01/09/2017	<0.2	µg / L	No
Chlorpyrifos	01/09/2017	<0.5	µg / L	No
Diazinon	01/09/2017	<1	µg / L	No
Dicamba	01/09/2017	<5	µg / L	No
1,2-Dichlorobenzene	01/09/2017	<0.1	µg / L	No
1,4-Dichlorobenzene	01/09/2017	<0.2	µg / L	No
1,2-Dichloroethane	01/09/2017	<0.1	µg / L	No
1,1-Dichloroethylene	01/09/2017	<0.1	µg / L	No
Dichloromethane	01/09/2017	<0.3	µg / L	No
2,4 Dichlorophenol	01/09/2017	<0.1	µg / L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	01/09/2017	<5	µg / L	No
Diclofop-methyl	01/09/2017	<0.5	µg / L	No
Dimethoate	01/09/2017	<1	µg / L	No
Diquat	01/09/2017	<5	µg / L	No
Diuron	01/09/2017	<5	µg / L	No
Glyphosate	01/09/2017	<25	µg / L	No
Malathion	01/09/2017	<5	µg / L	No
MCPA	01/09/2017	<0.00012	mg / L	No
Metolachlor	01/09/2017	<3	µg / L	No
Metribuzin	01/09/2017	<3	µg / L	No
Monochlorobenzene	01/09/2017	<0.2	µg / L	No
Paraquat	01/09/2017	<1	µg / L	No
Pentachlorophenol	01/09/2017	<0.1	µg / L	No
Phorate	01/09/2017	<0.3	µg / L	No
Picloram	01/09/2017	<5	µg / L	No

Polychlorinated Biphenyls (PCBs)	01/09/2017	<0.05	µg / L	No
Prometryne	01/09/2017	<0.1	µg / L	No
Simazine	01/09/2017	<0.5	µg / L	No
Terbufos	01/09/2017	<0.3	µg / L	No
Tetrachloroethylene	01/09/2017	<0.2	µg / L	No
2,3,4,6-Tetrachlorophenol	01/09/2017	<0.1	µg / L	No
Triallate	01/09/2017	<10	µg / L	No
Trichloroethylene	01/09/2017	<0.1	µg / L	No
2,4,6-Trichlorophenol	01/09/2017	<0.1	µg / L	No
Trifluralin	01/09/2017	<0.5	µg / L	No
Vinyl Chloride	01/09/2017	<0.2	µg / L	No

Distribution Water Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
THM (NOTE: show latest annual average)	10/16/17	10.9	µg / L	No
HAA (NOTE: show latest annual average)	10/16/17	8.0	µg / L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
n/a			